



Panoor Municipality

P.O Panoor, Pin-670692, Kannur District, Kerala State

email:- panoormunicipality2015@gmail.com, Ph-0490 2311340

H1/4464/22

Date: 19/05/2022

SANITATION CERTIFICATE

This is to Certify that the sanitation conditions of Sirajul Huda English Medium School, Puliyanambram, Panoor, Kannur (Dist.) are satisfactory at present.

This Certificate is issued to CBSE Affiliation purposes



Health Inspector
Panoor Municipality

[Handwritten signature]
19/5/2022
JITHESH KUMAR K. V.
Health Inspector Gr-I
PANOOR MUNICIPALITY



GEO WATER CLINIC

Water Quality Testing Laboratory, Noon Enterprises Building,
Main Road, Thalassery - 670101, Ph: 0490 - 2323131, 9400326111

Email: geowaterclinic@gmail.com

(Approved by Kerala State Pollution Control Board)

1345 ANALYSIS REPORT OF WATER SAMPLE



Test Report No. :

Date :

Sample type : DRINKING WATER.	Date and time of Sample : 13-04-2022 Collection
Source : OPEN WELL	Date and time of Sample : 13-04-2022 Receipt 10 AM
Customer Name : SIRAJULHUDA ENGLISH MEDIUM SCHOOL	Sample Container : PLASTIC BOTTLE
Customer Address : PERINGATHOOR	Sample Condition : GOOD
Ph: 9447825308	Test Method: APHA / IS

Test Date:

SI No.	PARAMETER	UNIT	TEST RESULT	DESIRABLE LIMIT As Per
01	PH @ 25°C	-	6.4	6.5 - 8.5
02	Conductivity @ 25°C	µs/cm	64	
03	Turbidity	NTU	0.4	5.0
04	Total Dissolved Solids	mg/L	62	500
05	Total Suspended Solids	mg/L		
06	Total Alkalinity	mg/L	16	200
07	Chloride	mg/L	28	250
08	Sulphate	mg/L		
09	Ammonia as Nitrogen	mg/L	BDL	0.5
10	Total Hardness	mg/L	16	300
11	Calcium hardness	mg/L	8.0	
12	Magnesium hardness	mg/L	8.0	
13	Calcium	mg/L	3.2	75
14	Magnesium	mg/L	1.9	30
15	Iron	mg/L	0.1	0.3
16	Manganese	mg/L		
17	COD	mg/L		
18	BOD	mg/L		
18	Oil & Grease	mg/L		
19	Total Coliform Bacteria	MPN/100 ml	NIL	
20	Fecal Coliform Bacteria	MPN/100 ml	NIL	

REMARKS:

PH IS LOW IN THE SAMPLE.

BDL: BELOW DETECTION LEVEL

GEO WATER CLINIC
Noon Enterprises Building
Near Mattambram Palli
Main Road, Thalassery-670101
Signature of Head of Laboratory
Signature of Lab Analyst